

✓


OFFICE OF CIVIL SURGEON HISAR

Hygienic and Sanitation certificate


No/HISR/DHO/HH/2023/ 29

Dated 01-03-2023


Certified that the condition of the building of
DR. RAM CHANDRA VIDYA PEETH SR SEC SCHOOL, MADAN HARI
.....HISAR with regards to the Sanitation and Hygienic condition is
satisfactory for the one year w.e.f date of issuing.

Attested


President
B.R. Memorial Vidyapeeth
Society (Regd.)
ROHTAK (Haryana)


Dy Civil Surgeon (Health)
o/c For Civil Surgeon, Hisar

Attested


Principal
Dr. Ram Chandra Vidyapeeth
Sr. Sec. School
MADAN HARI (Hisar)



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, HISAR

Website :- <https://phedharyana.gov.in/>

Memo No:- 197

Date:- 07/02/2023

Subject : **Physical / Chemical Examination Report of Water Sample**

HC-978

Sample ID/Classification : HSR/03661/2/2023 / Private		Sample Details	Date & Time
Sender :	Dr. Ramchandra Vidyapeeth Sr. Sec. School18308	Collected By	
Location :	, Madan-Heri	Collection Date	06/02/2023 at 11:31
Sample Description :	Drinking Water	Received at lab	06/02/2023 at 13:17
Latitude / Longitude :	76.220786 / 29.027793	Analysis Start Date	06/02/2023
		Analysis End Date	07/02/2023
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	46.50	500 mg/lit.	2000 mg/lit.	APHA2540 C; 2017
2	Total Hardness as CaCo3	17.6	200 mg/lit.	600 mg/lit.	APHA2340 C; 2017
3	Calcium as Ca	4.008	75 mg/lit.	200 mg/lit.	APHA3500-Ca B; 2017
4	Magnesium as Mg	1.84	30 mg/lit.	100 mg/lit.	APHA3500 Mg B; 2017
5	Iron as Fe	0.01	1.0 mg/lit.	1.0 mg/lit.	APHA3500-Fe B; 2017
6	Chloride as Cl	5.67	250 mg/lit.	1000 mg/lit.	APHA4500 Cl-B; 2017
7	Sulphate as So4	8	200 mg/lit.	400 mg/lit.	APHA4500-So4-E
8	Fluoride as F	0.09	1.0 mg/lit.	1.5 mg/lit.	APHA 4500-F--C
9	Nitrate as No3	0.19	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- D
10	pH @ 25°C	8.40	6.5 - 8.5	6.5 - 8.5	APHA4500-H+ B; 2017
11	Total Alkalinity	8.8	200 mg/lit.	600 mg/lit.	APHA 2320 B; 2017

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "**POTABLE**"



Sample analyzed by :

RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in

B.R. Memorial Vidyapeeth Society (Regd.)
ROHTAK (Haryana)

Principal
Dr. Ram Chandra Vidyapeeth
Sr. Sec. School
MADAN HERI (Hisar)

Page 1 of 1

END OF TEST REPORT